

2024年度 豊岡エコバレー・但馬空港地場ソーラー一月間発電状況

月	①月別予測 発電量 (kWh)	②実績発電 電力量 (kWh)	増減分 ②－① (kWh)	達成率 (%)
4	60,100	69,622	9,522	115.8
5	71,700	45,007	-26,693	62.8
6	61,900	67,303	5,403	108.7
7	67,700	66,870	-830	98.8
8	76,700	77,801	1,101	101.4
9	56,000	69,635	13,635	124.3
10	51,500	47,787	-3,713	92.8
11	31,000	43,769	12,769	141.2
12	19,300	34,658	15,358	179.6
1	8,200	37,852	29,652	461.6
2	10,600	19,365	8,765	182.7
3	35,300	57,830	22,530	163.8
合 計	550,000	637,499	87,499	115.9%