

2025年度 豊岡エコバレー・但馬空港地場ソーラー月間発電状況

月	①月別予測 発電量 (kWh)	②実績発電 電力量 (kWh)	増減分 ②－① (kWh)	達成率 (%)
4	60,100	65,573	5,473	109.1
5	71,700	70,817	-883	98.8
6	61,900	70,329	8,429	113.6
7	67,700	95,846	28,146	141.6
8	76,700	79,255	2,555	103.3
9	56,000	54,629	-1,371	97.6
10	51,500	33,089	-18,411	64.3
11	31,000	23,607	-7,393	76.2
12	19,300	15,966	-3,334	82.7
1	8,200	10,289	2,089	125.5
2	10,600	14,630	4,030	138.0
3	35,300	46,813	11,513	132.6
合 計	550,000	580,843	30,843	105.6%